

LIMITATIONS ON WASTEWATER STRENGTH (SMC TITLE 13 SECTION 36.090)

No person shall discharge wastewater containing constituents in excess of:

| Constituent | Maximum Conc. | Constituent | Maximum Conc. |
|------------------|---------------|-------------------------------|---------------------|
| Arsenic | 2.00 mg/l | Selenium | 0.06 mg/l |
| Barium | 14.00 mg/l | Silver | 0.05 mg/l |
| Boron | 1.00 mg/l | Zinc | 1.00 mg/l |
| Cadmium | 0.02 mg/l | Phenol | 2.5 mg/l |
| Chromium (total) | 0.50 mg/l | Other Phenolic Compounds | 0.005 mg/l |
| Copper | 0.50 mg/l | Alkalinity | 430.00 mg/l |
| Cyanide | 0.23 mg/l | Chloride | 110.00 mg/l |
| Iron | 90.00 mg/l | Fluoride | 4.00 mg/l |
| Lead | 0.30 mg/l | Sulfate | 240.00 mg/l |
| Manganese | 1.10 mg/l | Oil & Grease | 100.00 mg/l |
| Mercury | 0.01 mg/l | Animal/Vegetable Oil & Grease | 300.00 mg/l |
| Nickel | 1.80 mg/l | Temperature | 150 ⁰ F. |
| | | pH | 5.5 - 10.0 units |
| | | | |